



Environment Protection Licence No.: 1694

Link to full licence on EPA website:

<http://www.epa.nsw.gov.au/prpoeoapp/>

Licensee: Edward River Council, PO Box 270 Deniliquin NSW 2710

Address of facility: Calimo Street, Deniliquin NSW

Monitoring Point 1

Location: Outlet from the Northern end of the Pond 4 into the drainage channel

Date data Published: 25 July 2024

NOTE: No discharged was recorded from Point 1 for the reporting month of June due to the operation of the effluent reuse scheme. No samples were taken for analysis.

Monitoring Point 3

Location: Flow meter downstream of Pond 4 outlet

Date data Published: 25 July 2024

Monitoring Period 1st of June 2024 to 30th June 2024

NOTE: No flow was recorded at Point 3 for the reporting month of June due to the operation of the effluent reuse scheme.

Monitoring Point 4

Location: Effluent Reuse Pump Station adjacent Pond 4

Date data Published: 25 July 2024

Date data obtained: 24 June 2024

Date Sampled: 5 June 2024

Pollutant	Unit	Monitoring frequency required by licence	Measurement
Biochemical Oxygen Demand	mg/l	Monthly	15
Chlorophyll-a	mg/m ³	Monthly	88
Conductivity	uS/cm	Monthly	545
Escherichia coli	cfu/100ml	Monthly	88
Nitrogen (total)	mg/l	Monthly	14
Oil and Grease	mg/l	Monthly	1
pH	pH units	Monthly	7.6
Phosphorus (total)	mg/l	Monthly	6.84
Total Suspended Solids	mg/l	Monthly	7

Monitoring Point 5

Location: Flow meter downstream of Effluent Pump Station

Date data Published: 25 July 2024

Monitoring Period 1st of June 2024 to 30th June 2024

Item	Unit	Monitoring frequency required by licence	Min. value	Max. value	Volume limit	Exceeds limit (yes/no)
Daily flow	kl/day	continuous	1311	2721	4000	No

.....end of report